RADIATORS





ALL THERM

ELEMENTS PAINTED WITH CATAPHORESIS DOUBLE LAYER THIRD WORLD WIDE INDUSTRIAL GROUP TUV NF CONTROL CERTIFICATION 10 YEARS GUARANTY



LODEL	ISO 3147 - 3150										A	в	с	D	Е	F	G	WATER	WEIGHT
MODEL	150 5147 - 5150																		
DRY	∆T = 60°C			∆T = 50°C			∆T = 40°C											CAPACITY	ELEMENT
	WATT	KCAL/H	BTU/H	WATT	KCAL/H	BTU/H	WATT	KCAL/H	BTU/H	η	мм	ММ	MM	MM	мм	мм	INCH	LITRE	KG
350	128	110	436	100	86	343	75	64	255	1,323	429	350	97	80	25	120	1	0.34	0.95
500	160	138	547	127	109	432	95	82	324	1.292	579	500	97	80	25	120	1	0.44	1.20
600	189	163	646	148	127	506	110	94	374	1,348	679	600	97	80	25	120	1	0.52	1.42

Output in Watt/hr room temperature through tests according ISO 3147-3150.

D F

G

Other Output Q = Qu $\left(\frac{\Delta \tau}{60}\right)\eta$






ALL THERM (GIBRALTAR) LTD

HEADQUARTERS :

WORD

World Trade Center 6 Bayside Road 1st Floor – Unit 1.02 GX1 1AA Gibraltar & (+350) 200 60207 & info@allthermgroup.com



www.allthermgroup.com